



Uploaded to the VFC Website

▶▶▶ 2019 ◀◀◀

This Document has been provided to you courtesy of Veterans-For-Change!

Feel free to pass to any veteran who might be able to use this information!

For thousands more files like this and hundreds of links to useful information, and hundreds of "Frequently Asked Questions, please go to:

[Veterans-For-Change](#)

If Veterans don't help Veterans, who will?

Note:

VFC is not liable for source information in this document, it is merely provided as a courtesy to our members & subscribers.



UNCLASSIFIED ONLY

Mike Koppi

FACSIMILE TRANSMITTAL	HOLMES & NARVER, INC. ENERGY SUPPORT DIVISION PACIFIC OPERATIONS USDOE CONTRACT DE-AC08-86NV10471	FACSIMILE NO.: (808) 422-9259 VERIFICATION NO.: (808) 422-9251
-----------------------	--	---



COVER SHEET

DATE: MARCH 20, 1989

TO: JIA SUPPLY DEPT.
FACSIMILE NUMBER

TO: _____
VERIFICATION NUMBER

TO: JACK LIVINGSTON SUPPLY DEPT. JOHNSTON ATOLL
NAME ORGANIZATION/LOCATION

FROM: R. CREWE PURCHASING - HONOLULU 422-9253
SENDER'S NAME ORGANIZATION/LOCATION SENDER'S TELEPHONE NUMBER

THIS TRANSMITTAL CONSISTS OF 1 PAGES (EXCLUDING COVER SHEET)

SPECIAL INSTRUCTIONS

JACK: ATTACHED IS REPORT ON ASBESTOS CONTENT OF SAMPLE SENT ON REQ. 204042. PAUL KATZ OF UNITEK CAUTIONS THAT BECAUSE OF HIGH CONTENT WORK ON PROJECT SHOULD NOT BE RESUMED WITHOUT ADEQUATE CONTROL OF ASBESTOS. ALSO ANY FUTURE SAMPLES SENT IN FOR ASBESTOS ANALYSIS SHOULD BE NO LARGER THAN A SUGAR CUBE WHICH THEY KEEP UNDER CONTROL. THE BALANCE CAN'T BE DISPOSED OF EXCEPT BY APPROVED REGULATED METHODS. THEY ALSO NEED DETAILS ON WHAT THE PROJECT IS FOR THEIR RECORDS. ADVISE PLEASE

[Handwritten signature]



Unitek Environmental Consultants, Inc.

2889 Mokumoa Street
 Honolulu, Hawaii 96819
 Telephone: (808) 834-1448
 Fax Phone: (808) 830-0765



Bldg 20

*Joint Operations
 Center*

ASBESTOS REPORT

CLIENT: HOLMES & NARVER, INC.
ADDRESS: P.O. Box 29939
 Honolulu, HI 96820
CONTACT: Mr. R. E. Grewe
ORDERED BY: Client
SAMPLE LOCATION: Not given.

REPORT DATE: 3/20/89
JOB No.: 6313
PHONE: 422-9253
CLIENT JOB/P.O. No.: 20404201
DATE SAMPLED: 3/17/89

LABORATORY No.	SAMPLE DESCRIPTION:	ASBESTOS (MINERAL TYPE)
190317-01	B-0020	40% CHRYSOTILE (fiber glass mineral wool,
		cellulose)

REMARKS: Percentages are given for all samples containing asbestos. Samples were analyzed by polarized light microscopy with dispersal staining. Initial identification was performed by Ms. Claudia Burghardt on 3/20/89; results were verified by Mr. Paul W. Kath on 3/20/89.

L. Seto
 L. Seto


P. W. Kath

INFORMATION ONLY



FROM R.E. GREWE

MIKE
~~Jack~~



Info for your
file on asbestos
sample



3/21



HOLMES & NARVER, INC. - HONOLULU



Unitek Environmental Consultants, Inc.

2889 Mokumoa Street
Honolulu, Hawaii 96819
Telephone: (808) 834-1448
Fax Phone: (808) 838-0788



Bldg 20
Joint Operations
Center

ASBESTOS REPORT

CLIENT: HOLMES & NARVER, INC.
ADDRESS: P.O. Box 29939
Honolulu, HI 96820
CONTACT: Mr. R. E. Grewe
SAMPLED BY: Client
SAMPLE LOCATION: Not given.

REPORT DATE: 3/20/89
JOB No.: 6313
PHONE: 422-9253
CLIENT JOB/P.O. No.: 20404201
DATE SAMPLED: 3/17/89

LABORATORY No.	SAMPLE DESCRIPTION:	ASBESTOS (MINERAL TYPE)
8890317-01	B-0020	40% CHRYSOTILE (fiber glass mineral wool
		cellulose)

REMARKS: Percentages are given for all samples containing asbestos. Samples were analyzed by polarized light microscopy with dispersal staining. Initial identification was performed by Ms. Claudie Burghardt on 3/20/89; results were verified by Mr. Paul W. Kath on 3/20/89.

R. L. Beto
R. L. Beto

R. Unitek